



UNITED STATES PATENT AND TRADEMARK OFFICE

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office
Address: COMMISSIONER FOR PATENTS
P.O. Box 1450
Alexandria, Virginia 22313-1450
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
10/520,337	03/28/2005	Claus Thybo	6495-0090WOUS	2586
7590 McCorminck Paulding & Huber CityPlace II 185 Asylum Street Hartford, CT 06103-4102			EXAMINER KOCA, HUSEYIN	
			ART UNIT 3744	PAPER NUMBER
			MAIL DATE 10/04/2007	DELIVERY MODE PAPER

Please find below and/or attached an Office communication concerning this application or proceeding.

The time period for reply, if any, is set in the attached communication.

Office Action Summary

Application No.

10/520,337

Applicant(s)

THYBO ET AL.

Examiner

Huseyin Koca

Art Unit

3744

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --

Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS, WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

Status

- 1) ☒ Responsive to communication(s) filed on 05 January 2005.
- 2a) ☐ This action is **FINAL**. 2b) ☒ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

Disposition of Claims

- 4) ☒ Claim(s) 1-17 is/are pending in the application.
- 4a) Of the above claim(s) _____ is/are withdrawn from consideration.
- 5) ☐ Claim(s) _____ is/are allowed.
- 6) ☒ Claim(s) 1-17 is/are rejected.
- 7) ☐ Claim(s) _____ is/are objected to.
- 8) ☐ Claim(s) _____ are subject to restriction and/or election requirement.

Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☐ The drawing(s) filed on _____ is/are: a) ☐ accepted or b) ☐ objected to by the Examiner.
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

Priority under 35 U.S.C. § 119

- 12) ☒ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☒ All b) ☐ Some * c) ☐ None of:
1. ☐ Certified copies of the priority documents have been received.
 2. ☐ Certified copies of the priority documents have been received in Application No. _____.
 3. ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).

* See the attached detailed Office action for a list of the certified copies not received.

Attachment(s)

- 1) ☒ Notice of References Cited (PTO-892)
- 2) ☐ Notice of Draftsperson's Patent Drawing Review (PTO-948)
- 3) ☒ Information Disclosure Statement(s) (PTO/SB/08)
Paper No(s)/Mail Date 03/28/2005.

- 4) ☐ Interview Summary (PTO-413)
Paper No(s)/Mail Date. _____
- 5) ☐ Notice of Informal Patent Application
- 6) ☐ Other: _____

DETAILED ACTION

Claim Rejections - 35 USC § 101

1. 35 U.S.C. 101 reads as follows:

Whoever invents or discovers any new and useful process, machine, manufacture, or composition of matter, or any new and useful improvement thereof, may obtain a patent therefor, subject to the conditions and requirements of this title.

Claims 1-11 ^{ARE} ~~is~~ rejected under 35 U.S.C. 101 because the claimed invention is directed to non-statutory subject matter. In order for a method to be statutory it must show a practical application of an otherwise abstract data. In order to meet this requirement it must (a) show a practical application through a physical transformation or (b) other produce a useful, concrete and tangible result. A physical transformation can be shown if the method transforms an article or physical object into a different state or thing. In the presently claimed invention each of the method steps is intended to be performed in a computer, the human mind, or with the aid of a pencil and paper. There is no physical object which can be or is transformed. Further, the presently claimed invention fails to produce a concrete result. Claim 1 includes the limitation "establishing an energy balance from which a parameter for monitoring the refrigerant flow is derived." Claim invention does not produce a tangible result.

Claim Rejections - 35 USC § 103

2. The following is a quotation of 35 U.S.C. 103(a) which forms the basis for all obviousness rejections set forth in this Office action:

(a) A patent may not be obtained though the invention is not identically disclosed or described as set forth in section 102 of this title, if the differences between the subject matter sought to be patented and the prior art are such that the subject matter as a whole would have been obvious at the time the

Art Unit: 3744

invention was made to a person having ordinary skill in the art to which said subject matter pertains. Patentability shall not be negated by the manner in which the invention was made.

3. The factual inquiries set forth in *Graham v. John Deere Co.*, 383 U.S. 1, 148

USPQ 459 (1966), that are applied for establishing a background for determining

obviousness under 35 U.S.C. 103(a) are summarized as follows:

1. Determining the scope and contents of the prior art.
2. Ascertaining the differences between the prior art and the claims at issue.
3. Resolving the level of ordinary skill in the pertinent art.
4. Considering objective evidence present in the application indicating obviousness or nonobviousness.

4. Claims 1-9 are rejected under 35 U.S.C. 103(a) as being unpatentable over

Stoecker (Industrial Refrigeration Handbook), and further in view of Cengel

(Thermodynamics).

In regard to claims 1 and 4-7, Stoecker teaches detecting a flash gas in vapour-compression refrigeration comprising a compressor, a condenser, and expansion device, and an evaporator interconnected by conduits providing a flow path for a refrigerant (Pages 64-68). Stoecker teaches using thermodynamics characteristics of a heat exchanger but does not teach the details of establishing an energy balance.

Cengel teaches determining a rate of heat flow of a heat exchange fluid across a heat exchanger and forming an energy balance in detail (Pages 193-195). It would have been obvious to one having ordinary skill in the art at the time the invention was made to detect flash gas using thermodynamics properties of the refrigerant since it has direct relation with cause of flash gas. Establishing an energy balance is a well-known method and it is the 1st Law of Thermodynamics. Additionally, it would have been obvious to one having ordinary skill in the art at the time the invention was made to determine the

Art Unit: 3744

mass flow and the specific enthalpy because they are obvious mechanical expedient and one ordinary skilled artisan would normally calculate these parameters for the purpose of studying or varying the flow characteristics.

In regard to claims 2 and 3, Cengel teaches determining rate of heat across a heat exchanger (Pages 193-195). Since the evaporator and the condenser are both heat exchangers it would have been obvious to one having ordinary skill in the art at the time the invention was made to determined rate of heat flow of heat exchange fluid flow across a heat exchanger (which might be evaporator or a condenser) in order to establish an energy balance equation.

In regard to claim 8, Stoecker teaches that the flash gas develops as the expansion proceeds (Page 65). Therefore, it would have been obvious to one having ordinary skill in the art at the time the invention was made to establish the refrigerant mass flow based on a flow characteristics of the expansion device, the expansion device opening passage and/or opening period, and an absolute pressure before and after the expansion device in order to detect and remove flash gas from the system.

In regard to claim 9, see the rejection for claims 1 and 8 above.

5. Claims 10 and 12-17 are rejected under 35 U.S.C. 103(a) as being unpatentable over Stoecker (Industrial Refrigeration Handbook) in view of Cengel (Thermodynamics) as applied to claim 1 above, and further in view of Seem (6,223,544).

In regard to claim 10,12, and 16, Stoecker in view of Cengel teach most of the limitations of the claim but do not explicitly teach establishing a residual and generating a signal. Seem teaches establishing a residual based on energy balance and indicating

Art Unit: 3744

a problem with the system (C-6, L-25-67; C-7, L-1-20; Fig. 3). Therefore, it would have been obvious to one having ordinary skill in the art at the time the invention was made to establish a residual as taught by Seem in the system of Stoecker in view of Cengel in order to advantageously determine the problems in the system.

6. Claim 11 is rejected under 35 U.S.C. 103(a) as being unpatentable over Stoecker (Industrial Refrigeration Handbook) in view of Cengel (Thermodynamics) and Seem (6,223,544) as applied to claim 10 above, and further in view of Parlos et al. (6,590,362).

In regard to claim 11, Stoecker, Cengel, and Seem teaches most of the limitations of the claim but do not explicitly teach a fault indicator equation. However, obtaining fault indicator equation for different apparatuses is within the skill and knowledge of one having ordinary skill in the art. An example of this can be seen by Parlos et al. where Parlos et al. teach a fault indicator equation for detecting the mechanical faults (C-7, L-1-8). Therefore, it would have been obvious to one having ordinary skill in the art at the time the invention was made to obtain a fault indicator equation in order to determine the faults with the system.

In regard to claims 13-15, see the rejection for claims 1 and 4-7.

In regard to claim 17, Stoecker in view of Cengel teach most of the limitations of the claim but do not explicitly teach comparing output signal with a previously stored output signal. Seem teaches comparing output signal with a previously stored output signal (C-1, L-60-67; C-2, L-55-61). It would have been obvious to one having ordinary skill in the art at the time the invention was made to compare output signal with a

Art Unit: 3744

previously stored output signal as taught by Seem in order to advantageously determine the operation condition of the system.

Conclusion


7. Any inquiry concerning this communication or earlier communications from the examiner should be directed to Huseyin Koca whose telephone number is (571) 272-3048. The examiner can normally be reached on Monday - Friday 9:00AM to 4:00PM.

8. If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Cheryl Tyler can be reached on (571) 272-4834 or Frantz Jules (571) 272-6681. The fax phone number for the organization where this application or proceeding is assigned is 571-273-8300.

9. Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see <http://pair-direct.uspto.gov>. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free). If you would like assistance from a USPTO Customer Service Representative or access to the automated information system, call 800-786-9199 (IN USA OR CANADA) or 571-272-1000.

/HK/

FRANTZ JULES
SUPERVISORY PATENT EXAMINER

A handwritten signature in black ink, appearing to read 'Frantz Jules', is written over the printed name and title of the Supervisory Patent Examiner.